
JTAS (2020) 3:16 **Research Article**



Journal of Theoretical and Applied Sciences (ISSN:2637-692X)



Optimal Solution in Generator Selection

Zhong Zheng¹*, Yu Cao², Hairui Zhang², Weiming Jing³, Qian Cao⁴

¹College of Electrical Engineering & New Energy, China Three Gorges University, Yichang, 443002, China.

²College of Science, China Three Gorges University, Yichang, 443002, China.

ABSTRACT

This paper focuses on the application of nonlinear programming *Correspondence to Author: in solving the optimal selection strategy of generator. A Zhong Zheng nonlinear programming model for optimal scheme selection College of Electrical Engineering & was established. Comparative analysis, numerical combination New Energy, China Three Gorges analysis and sensitivity analysis were used to solve the problem, University, Yichang, 443002, China. and MATLAB, LINGO and other software were used to assist the calculation. According to the actual background provided in this paper, it can be concluded that the minimum cost of this How to cite this article: factory in a week of power failure is 1868443.7 yuan without Zhong Zheng, Yu Cao, Hairui charging. If the remaining 20% of the battery is taken into Zhang, Weiming Jing, Qian account, the minimum charge is 2575502.0 yuan. After obtaining the results, the sensitivity analysis was carried out to improve the Selection. Journal of Theoretical practicability of the results.

Keywords: Nonlinear programming model; Sensitivity analysis; Numerical combination analysis

Cao. Optimal Solution in Generator and Applied Sciences, 2020, 3:16



³College of Computer and Information Technology, China Three Gorges University, Yichang, 443002, China.

⁴College of Foreign Languages, China Three Gorges University, Yichang, 443002, China.

1. Introduction

A generator is a device that converts other forms of energy into electricity. In the actual production process, the generator can supply power to almost all electric equipment and charge the battery at the same time. In order to ensure the production efficiency in the factory, it is usually equipped with the generator set to meet the requirements as backup or emergency power supply. Therefore, the reasonable use of generators is of great significance to the production of factories. The problem of generator selection can be regarded as a problem of finding the optimal solution of production cost. In this paper, a nonlinear programming model is established to solve the problem. Combined with the following examples:

A large plant will be without power for a week as a result of a power upgrade, forcing it to run four different types of generators to meet its daily demand. Given the daily power needs of the plant, the plant has four types of generators to choose from, each with a different generating capacity, and each with a maximum generating capacity that, when connected to the grid, should not fall below a certain minimum output.

All generators have a start-up cost and a fixed hourly cost for operating at the minimum power state, and if the power is above the minimum, there is a cost per kilowatt per hour for the excess power, called marginal cost.

Generators are allowed to be started or shut

down only at the beginning of each session. Unlike starting a generator, there is no cost involved in shutting it down. In the selection process, various factors need to be taken into account comprehensively, and the electricity demand of each time period is different. If the case of charging to the battery is not considered, an alternative scheme can be determined, but if charging to the battery is considered, a margin of 20% of the generating capacity needs to be set aside, and another scheme is required.

2. Model assumptions

Hypothesis 1: in each time period, the output power of the generator is stable.

Hypothesis 2: there is no loss of power in the transmission line.

Hypothesis 3: the generator is turned on and off instantaneously.

Hypothesis 4: there is no limit on the working hours of the generator.

3. Problem analysis

Solve the problem of reasonable selection of generators, list the restriction conditions according to the problem, and work out the specific plan, that is, work out which generators should be used in each period to minimize the total cost of a week. The number of generators, power demand, whether to charge the battery and other conditions can be used as constraints. Total costs are the sum of fixed costs, start-up costs, and marginal costs. The details are as follows:




Fig.1: Total cost structure diagram

There is a repetition problem in the calculation process, that is, the machine working in each time period may also need to work in the previous time period, so it can be divided (Fig.2). Through classified as you can see, in every between two periods there might be a

repeat of the machine working situation, the processing mode is given based on the calculation of each time period is to restart the machine, then respectively calculate the best measures to each time period, after a detailed analysis of each time period is likely to repeat the number of machines and cost minus the repeated work of the machine work, finally get the minimum cost.




Fig.2: Machine work repeats

After the optimal scheme is calculated, the sensitivity of the scheme is analyzed, and the result is extended according to the actual situation to obtain the final result.

4. Data collection and processing

The daily power demand of the plant is shown in Table 1.

Table 1. Daily defilate (kw)									
Time frame (0-24)	0-6	6-9	9-12	12-14	14-18	18-22	22-24		
Demand	11000	33000	25000	36000	25000	30000	18000		

Table 1: Daily demand (kw)

The generator situation is shown in Table 2.

Table 2: Generators

	Available quantity	Minimum output	Maximum output	Fixed cost	Marginal cost	Start-up cost
Type 1	10	800	1800	2200	2.7	4000
Type 2	5	1000	1500	1800	2.2	1500
Type 3	8	1200	2000	3800	1.8	2500
Type 4	4	1800	3500	4600	3.6	1000

Note: maximum output and minimum output are maximum output power (kw) and minimum output power (kw); Fixed cost, marginal cost (yuan/hour); Fixed cost (yuan).

If a working generator set must set aside 20% of demand for each period is shown in the table beits generating capacity to charge the battery, the low:

Table 3: Minimum power generation (kw)

Time frame (0-24)	0-6	6-9	9-12	12-14	14-18	18-22	22-24

Demand	13750	41250	31250	45000	31250	37500	22500

5. Model building

5.1 Theoretical foundation

A. Nonlinear programming: nonlinear programming is a method of solving optimization problems in which one or more nonlinear functions are present in the objective function or constraint. Combined with the practical problems studied in this paper, the objective function, constraint conditions and decision variables were found, and the optimal solution was solved by MATLAB and LINGO.

B. Sensitivity analysis: sensitivity analysis is a method of studying and analyzing the sensitivity of a model's state or output changes to system parameters. It can also be understood as the size of the dependency on the relevant parameters in the model. Sensitivity analysis is often used in optimization methods to study the stability of the optimal solution when the original data

is inaccurate or changes. Sensitivity analysis can also determine which parameters have a greater impact on the system or model.

5.2 Modeling

According to the analysis of the actual problem, the minimum total cost should be calculated. The given data include the situation of the generator and the daily demand for electricity. Then the key to solve the problem is to distribute the motor reasonably in each time period according to the situation of the motor. The nonlinear programming model is established through analysis, the objective function and constraint conditions are listed with the data given by the problem, and the optimal solution is obtained by software calculation.

To establish a nonlinear programming model, the specific steps are as follows:

a. Characterizing objective function:

Start-up cost:

$$Q = \sum_{i=1}^{I'} \sum_{j=1}^{J'} f_j \cdot a_{ij} - \sum_{j=1}^{J'} \sum_{i=2}^{I'} f_j \cdot \min(a_{ij}, a_{(i-1)j})$$

Type, Q represents the startup cost;

 $f_{\it j}$ is the starting cost of model $\it j$ machine;

 a_{ij} is the number of model j machine in the i th time period;

i represents the time period;

j representative machine model;

 $\min \left(a_{ij}, a_{(i-1)j} \right)$ is the minimum value of the number of model j machines in two adjacent time periods.

Fixed costs for period i:

$$G_i = \sum_{j=1}^{J'} h_i \cdot \left(a_{ij} \cdot k_j \right)$$

Total fixed cost:

$$G = G_1 + G_2 + \dots + G_{j'} = \sum_{i=1}^{j'} \sum_{j=1}^{j'} h_i \cdot (a_{ij} \cdot k_j)$$

Type, k_j represents the fixed cost of model j machine;

 h_i represents the time of the i th time period;

 G_i represents the fixed cost of the $\,i$ th period;

I represents the period number;

J represents the number of machine

models:

Where, the total fixed cost is accumulated from the fixed cost of each time period, and the fixed cost of each time period is multiplied by the number of machines of the model multiplied by the operating time of the model machine multiplied by the fixed cost of the model machine per hour; Marginal cost in the i th time period:

$$D_{i} = \sum_{j=1}^{J} (x_{ij} - n_{j}) \cdot a_{ij} \cdot h_{i} \cdot J_{j}$$

Total marginal cost:

$$D = D_1 + D_2 + \dots + D_I = \sum_{i=1}^{I} \sum_{j=1}^{J} (x_{ij} - n_j) \cdot a_{ij} \cdot h_i \cdot J_j$$

Type, D_i represents the marginal cost of the i th time period;

 J_j represents the marginal cost per kilowatt of model j machine;

 n_j represents the minimum output power of model j machine;

 x_{ij} represents the output power of model j in the i th time period;

Where, the total marginal cost is derived from

the incremental marginal cost of each time period, and the marginal cost of each time period is derived from the partial power exceeding the minimum output power of the machine multiplied by the number of machines multiplied by the operating time of the machine multiplied by the marginal cost per kilowatt.

b. List the constraints:

A. If do not consider to the battery charge, then:

$$\sum_{i=1}^{J'} x_{ij} \cdot a_{ij} \ge e_i$$

Type, e_i represents the actual power required in the i th time period; The output power of the

selected scheme is greater than or equal to the actual required power.

$$n_i \leq x_{ii} \leq m_i$$

Type, n_j represents the minimum output power of model j machine, m_j represents the maximum output power of model j machine; The

actual power of each machine in the selected scheme should be between the minimum and maximum power.

$$x_{ii} = 0(a_{ii} = 0)$$

If the machine of a certain type has no power output, the number of the machine of that type in

that period is 0.

$$0 \le a_{ii} \le c_i$$

Type, c_j represents the total number of machines available for model j; The number of machines for each model in the selection should be between 0 and the alternative.

c. The optimal solution and value of the objective

function are obtained in the feasible domain. To sum up,

The objective function is: Z = G + Q + D

The constraint conditions are:

$$\begin{cases} \sum_{j=1}^{j'} x_{ij} \cdot a_{ij} \ge e_i \\ n_j \le x_{ij} \le m_j (a_{ij} \ne 0) \\ x_{ij} = 0 (a_{ij} = 0) \\ 0 \le a_{ij} \le c_j \end{cases}$$

B. If 20% charge is considered to the battery, the remaining 80% is used for normal power

generation, then:

Change the constraint:

$$\left(\sum_{i=1}^{4} x_{ij} \cdot a_{ij}\right) \cdot 80\% \ge e_i$$

Eighty percent of the actual power of the chosen scheme is greater than or equal to the actual power required.

To sum up,

The objective function is: Z = G + Q + D

The constraint conditions are:

$$\begin{cases} x_{ij} = 0(a_{ij} = 0) \\ n_j \le x_{ij} \le m_j (a_{ij} \ne 0) \\ 0 \le a_{ij} \le c_j \\ \left(\sum_{j=1}^{J} x_{ij} \cdot a_{ij}\right) \cdot 80\% \ge e_i \end{cases}$$

6. Model solution and result analysisA. Do not consider charging the battery(1) To solve the model

It is calculated that the minimum total cost of the first day is 241,439.7 yuan, the minimum total

cost of the second day is 273,834.0 yuan, the minimum total cost of the third day to the seventh day is 27,0634.0 yuan, and the minimum total cost of the week is 1868443.7 yuan. See the table below for details:

Table 4: Daily and total minimum cost

The first day	The second day	The third day	 The seventh day	Combined
241439.7	273834.0	270634.0	 270634.0	18,684,43.7

Note: Unit yuan

LINGO was used to calculate the distribution results of the previous two days' plans, and the matching plans of different models of machines

on the first day and the second day were obtained as follows:

Table 5: Options on the first day (quantity)

Time frame(h)	0-6	6-9	9-12	12-14	14-18	18-22	22-24
Type 1	0	10	10	10	0	0	0
Type 2	5	5	5	5	5	5	5
Type 3	2	8	8	8	8	8	6
Type 4	1	4	0	4	4	4	1

Note: The unit is a




Fig.3: Options on the first day (quantity)

Table 6: Machine power of different models on the first day

Time frame(h)	0-6	6-9	9-12	12-14	14-18	18-22	22-24
Type 1	0	801	800	800	0	0	0
Type 2	1500	1500	1450	1500	1500	1500	1500
Type 3	2000	2000	2000	2000	2000	2000	2000
Type 4	2250	2435	1800	3375	1938	3500	3000

Note: The digital unit is kilowatt.

The selection plan of the second day is as follows

Table 7: Options on the second day (quantity)

Time frame(h)	0-6	6-9	9-12	12-14	14-18	18-22	22-24
Type 1	5	10	10	10	10	0	0
Type 2	5	5	5	5	5	5	5
Type 3	8	8	8	8	8	8	8
Type 4	4	4	4	4	4	4	4

Note: The unit is a

As can be seen from the above table, the second day's selection scheme is the same as the first day. After analysis, the choice plan for the next few days of this week should be the same as that for the next day, so the choice plan for the seven days of this week is the same, all of which are the choices in the above table. The total cost of the first day and the second day is 283,426.0 yuan and 27,0816.0 yuan respectively, which is

in line with the previous mentioned in this paper. The total cost of the second day and the second day are the same.

(2) Sensitivity analysis

Sensitivity analysis was carried out on the results. The fixed cost of the first type of machine was fluctuated up and down within a certain range. The corresponding total cost of each fixed cost was corresponding to it.




Fig.4: The results were fitted on the first day

The fitting results of the second day are as follows:




Fig.5: Fitting results on the second day

Except the first day, the fitting results from the second day to the seventh day are all higher, indicating that the total cost is highly dependent on the fixed cost. When the fixed cost changes, the total cost also changes similarly.

B. Consider charging a battery

(1) To solve the model

It is calculated that the lowest cost of the first day is 375986.0 yuan, the lowest cost of the second day to the seventh day is 366586.0 yuan, and the lowest total cost of the week is 2575502.0 yuan, as shown in the following table:

Table 8: Daily and total minimum cost

The first day	The second day	The third day	 The seventh day	Combined
375986.0	366586.0	366586.0	 366586.0	2575502.0

Note: Unit yuan

The minimum total cost for the first day is different from that for the other six days, and the minimum total cost for the second to seventh day is the same.

LINGO was used to calculate the distribution

results of the previous two days' plans, and the matching plans of different models of machines on the first day and the second day were obtained as follows:

Table 9: Options on the first day (quantity)

Time frame(h)	0-6	6-9	9-12	12-14	14-18	18-22	22-24
Type 1	5	10	10	10	10	5	5
Type 2	5	5	5	5	5	5	5
Type 3	8	8	8	8	8	8	8
Type 4	4	4	0	4	4	4	4

Note: The unit is a




Fig.6: Options on the first day (quantity)

Table 10: Machine power of different models on the first day

Time frame(h)	0-6	6-9	9-12	12-14	14-18	18-22	22-24
Type 1	1500	800	800	800	800	1500	1500
Type 2	1500	1500	1500	1500	1500	1500	1500
Type 3	2000	2000	2000	2000	2000	2000	2000
Type 4	3500	3375	1800	3375	3375	3500	3500

Note: The digital unit is kilowatt.

(2) Sensitivity analysis

Sensitivity analysis was conducted on the calculation results, the fixed cost of the first machine

was changed to float within a certain range, and the fixed cost of the machine was fitted with the total cost. The specific results are as follow




Fig.7: The results were fitted on the first day

The fitting results of the second day are as follows:




Fig.8: Fitting results on the second day

The fitting effect is similar from the second day to the seventh day. Through the above fitting, the effect of the first day is excellent, and the effect of the next few days is reasonable, indicating that the total cost is highly dependent on the fixed cost. In the actual production process, we must ensure the reasonable fixed cost.

7. Model evaluation

7.1 Advantages of the model

- (1) Nonlinear programming is a mathematical method to assist people in scientific management. The knowledge of nonlinear programming is very helpful to solve optimization problems.
- (2) The model can meet a variety of practical conditions by adjusting constraints and objective functions, showing strong flexibility. Moreover, it can use mature linear programming tools to solve the problem in a simple and quick way, which is an effective means to assist decision-making.
- (3) The sensitivity analysis was used to test the

optimal solution, which enhanced the feasibility of the optimal solution calculated in this paper.

7.2 Disadvantages of the model

- (1) Nonlinear programming is mainly affected by constraint conditions and objective functions. If the constraint conditions are not obvious or there are many constraints and some can only be ignored, the optimal solution obtained is not necessarily the only optimal solution, which will have some influence on the decision-making.
- (2) In practice, there will be a climbing process in the start of the generator, but it cannot be considered in this paper. Therefore, there will still be some errors in obtaining the optimal solution

8. Improvement and promotion of the model8.1 Model improvement

(1) According to the various data of each type of generator given in the question, various data of similar generators are searched to serve as the basis for its climbing calculation, so as to reduce the error of the optimal solution obtained by climbing factors and enhance the feasibility of the obtained scheme;

- (2) The working time of the generator is limited, so in order to enhance the feasibility of the obtained scheme in real life, we need to search for information and increase the running time of each machine;
- (3) The power demand of the factory may also change in each period of the day, so we can increase the range of power demand and add a constraint:
- (4) In this paper, power calculation considers the output power of each generator as an integer, so non-integer calculation can be added to reduce the error.

8.2 Model generalization

- (1) Nonlinear programming can also be applied to the co-taxi scheduling problem to reduce the empty driving rate of taxis in urban traffic, improve the carrying efficiency of taxis and make full use of road resources;
- (2) The linear programming model can also be used to reduce the operation and maintenance cost of the fault indicator and the outage time of the distribution network;
- (3) The method of linear programming can also be used to optimize the technical parameters of autoclaved fly ash brick, so as to effectively improve the optimization accuracy.

9. Conclusion

This paper studies the application of nonlinear programming model in generator selection. Combined with an example, the established model is used to calculate that the minimum charge is 1868443.7 yuan if battery charging is not taken into account. If the battery is charged 20% and the remaining 80% is used for normal production, the minimum cost is 2575502.0 yuan. Based on the sensitivity analysis of the results, it is concluded that the fixed cost of generator is more important to the total production cost. Therefore, in the actual production process, the fixed cost of the generator itself should be kept as stable as possible to reduce its fluctuation.

References

 Sen Tian. Research on generation - coal cost model based on linear programming technology[J]. Business management, 2017(S2):249-

- 251.
- 2. Huichun Li, Zhemin Li, Ziyang Mao. A combined taxi dispatching model based on integer linear programming[J]. Transportation research, 2018, 4(05):35-42.
- Chao Cai, Jianzhong Ding, Feng Lv, Haixing Yuan, Ying Zhu, Guoqiang Sun, Zhinong Wei. Optimization of distribution network fault indicator based on integer linear programming model [J/OL]. Power system protection and control: 1-9[2019-07-17].
- Ying Zhao, Jing Gao. Theoretical thinking of sensitivity analysis and its application in business decision-making[J]. Radio and television university institute of technology, 2005(04):17-18+20.
- Shengping Yu, Qinghua Wu, Kun Liu, Jiahao Chen. A test method for infinitely many optimal solutions of linear programming models[J]. Journal of hubei university for nationalities (natural science edition), 2017,35(03):278-281.

